



NOTES:
 WHERE CONTAINMENT BACKFLOW PREVENTION
 DEVICE USED IS RPZD, MAINTAIN MINIMUM OF 300MM
 FROM THE VENT TO THE GROUND

DRAWING NUMBER:

20

SCALE:

NOT
TO
SCALE

DATE:

MARCH
2022

MINIMUM CLEARANCE FOR PRIVATE FIRE SERVICE
METER ASSEMBLIES



300MM
PROPER